Matt Tennenbaum, Answers to UL Questions

Q: Kitchen Suppression: If I understand correctly, where the duct length between hood interface and fan exceeds 75 feet, then additional duct nozzle(s)and detector(s) are required. Is that a fact? Do manufacturer's manuals reflect this? I am accustomed to seeing "ducts of unlimited length" referred to in the manuals.
[MDT] The concept of “ducts of unlimited length” simply refers to the fact that full scale hood & duct testing conducted in accordance with UL 300 was done with a minimum duct length of 75 ft, which is intended to represent any length of duct, even exceeding 75 ft. The installation of heat detectors and nozzles is to be done in accordance with NFPA 17A, NFPA 96 and the manufacturer’s installation manual. Additional devices are not required beyond any specific distance unless specifically required by one of those documents.

Q: Have the Rusoh rechargeable fire extinguishers been UL tested / certified
[MDT] I believe that this is in reference to “Eliminator” which has a series of UL Listed cartridge operated dry chemical fire extinguishers. Please look for the UL Listing Mark on the label. You can use the label information, including the model number or UL File Number, to confirm the reference on the UL Product iQ™ database.